



Saturday, February 28, 2026

Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Project ID:
SDG ID: GCV39060
Sample ID#s: CV39060 - CV39070

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style.

Phyllis Shiller
Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Sample Id Cross Reference

February 28, 2026

SDG I.D.: GCV39060

Project ID:

Client Id	Lab Id	Matrix	Col Date
398 LIBERTY ST	CV39060	DRINKING WATER	03/02/26 11:05
87 WEST BROAD ST	CV39061	DRINKING WATER	03/02/26 11:22
197 MECHANIC ST	CV39062	DRINKING WATER	03/02/26 11:45
416 BRADFORD RD	CV39063	DRINKING WATER	03/02/26 14:00
169 WESTERLY BRADFORD RD	CV39064	DRINKING WATER	03/02/26 13:46
249 POST RD	CV39065	DRINKING WATER	03/02/26 13:31
3 INDIA POINT RD	CV39066	DRINKING WATER	03/02/26 13:10
110 OAK STREET	CV39067	DRINKING WATER	03/02/26 12:39
114 ASHAWAY RD	CV39068	DRINKING WATER	03/02/26 12:20
8 PARKVIEW	CV39069	DRINKING WATER	03/02/26 12:04
68 WHITE ROCK RD	CV39070	DRINKING WATER	03/02/26 14:20



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

11:05
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39060

Project ID:
Client ID: 398 LIBERTY ST

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.97	0.01	1	mg/L		4		03/02/26 11:05	*	SM4500Cl-G-00
pH	7.7	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

11:22
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39061

Project ID:
Client ID: 87 WEST BROAD ST

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.90	0.01	1	mg/L		4		03/02/26 11:22	*	SM4500Cl-G-00
pH	7.6	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

11:45
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39062

Project ID:
Client ID: 197 MECHANIC ST

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.50	0.01	1	mg/L		4		03/02/26 11:45	*	SM4500Cl-G-00
pH	7.6	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

14:00
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39063

Project ID:
Client ID: 416 BRADFORD RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	1.06	0.01	1	mg/L		4		03/02/26 14:00	*	SM4500Cl-G-00
pH	7.9	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: SW
 Analyzed by: see "By" below

Date

03/02/26
 03/02/26

Time

13:46
 16:05

Laboratory Data

SDG ID: GCV39060
 Phoenix ID: CV39064

Project ID:
 Client ID: 169 WESTERLY BRADFORD RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.91	0.01	1	mg/L		4		03/02/26 13:46	*	SM4500Cl-G-00
pH	7.9	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

13:31
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39065

Project ID:
Client ID: 249 POST RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.85	0.01	1	mg/L		4		03/02/26 13:31	*	SM4500Cl-G-00
pH	7.5	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

13:10
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39066

Project ID:
Client ID: 3 INDIA POINT RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 17:20	AP1/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.21	0.01	1	mg/L		4		03/02/26 13:10	*	SM4500Cl-G-00
pH	7.7	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

12:39
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39067

Project ID:
Client ID: 110 OAK STREET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.76	0.01	1	mg/L		4		03/02/26 12:39	*	SM4500Cl-G-00
pH	7.5	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

12:20
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39068

Project ID:
Client ID: 114 ASHAWAY RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.46	0.01	1	mg/L		4		03/02/26 12:20	*	SM4500Cl-G-00
pH	7.7	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: SW
 Analyzed by: see "By" below

Date

03/02/26
 03/02/26

Time

12:04
 16:05

Laboratory Data

SDG ID: GCV39060
 Phoenix ID: CV39069

Project ID:
 Client ID: 8 PARKVIEW

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:39	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	0.66	0.01	1	mg/L		4		03/02/26 12:04	*	SM4500Cl-G-00
pH	7.5	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102

Analysis Report

February 28, 2026

FOR: Attn: Mr. Max Sposato
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
Location Code: WESTERLY
Rush Request: Standard
P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
Received by: SW
Analyzed by: see "By" below

Date

03/02/26
03/02/26

Time

14:20
16:05

Laboratory Data

SDG ID: GCV39060
Phoenix ID: CV39070

Project ID:
Client ID: 68 WHITE ROCK RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		03/02/26 18:35	HS/EK	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	03/02/26 19:40	KG	SM2120B-21
Odor at Room Temperature	< 1	1	1	T.O.N.			3	03/02/26 19:40	KG	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	03/02/26 19:43	KG	SM2130B-20
Chlorine Residual	1.37	0.01	1	mg/L		4		03/02/26 14:20	*	SM4500Cl-G-00
pH	7.6	1.00	1	pH Units			6.5-8.5	03/02/26	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141 MCLs; 40 CFR Part 141 MRDLs. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141 Monitoring; 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

March 05, 2026

Reviewed and Released by: Makrina Nolan



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102

QA/QC Report

March 05, 2026


QA/QC Data

SDG I.D.: GCV39060

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 828381 (NTU), QC Sample No: CV38782 (CV39060, CV39061, CV39062, CV39063, CV39064, CV39065)													
Turbidity	BRL	0.20	<0.20	<0.20	NC	101						85 - 115	20
QA/QC Batch 828380 (NTU), QC Sample No: CV39066 (CV39066, CV39067, CV39068, CV39069, CV39070)													
Turbidity	BRL	0.20	<0.20	<0.20	NC	101						85 - 115	20

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference
- (ISO) - Isotope Dilution


 Phyllis Shiller, Laboratory Director
 March 05, 2026

Thursday, March 05, 2026

Criteria: RI: DW

State: RI

Sample Criteria Exceedances Report

GCV39060 - WESTERLY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

March 05, 2026

SDG I.D.: GCV39060

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

