



Wednesday, January 13, 2021

Attn: Mr. Bill Beauregard
Westerly Water Department
68 White Rock Road
Westerly, RI 02891

Project ID:
SDG ID: GCH43911
Sample ID#s: CH43911 - CH43917

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style with a large initial "P".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
UT Lab Registration #CT00007
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Sample Id Cross Reference

January 13, 2021

SDG I.D.: GCH43911

Project ID:

Client Id	Lab Id	Matrix
398 LIBERTY ST	CH43911	DRINKING WATER
87 WEST BROAD ST	CH43912	DRINKING WATER
197 MECHANIC ST	CH43913	DRINKING WATER
249 POST RD	CH43914	DRINKING WATER
20 AVONDALE RD	CH43915	DRINKING WATER
110 OAK STREET	CH43916	DRINKING WATER
114 ASHAWAY RD	CH43917	DRINKING WATER



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

11:30
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43911

Project ID:
 Client ID: 398 LIBERTY ST

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	01/11/21 22:06	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	1.19	0.01	1	mg/L		4		01/11/21 11:30	*	SM4500Cl-G-00
pH	8.0	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

11:49
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43912

Project ID:
 Client ID: 87 WEST BROAD ST

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	5.00	1	1	Color Units			15	01/11/21 22:07	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	0.92	0.01	1	mg/L		4		01/11/21 11:49	*	SM4500Cl-G-00
pH	7.7	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

12:02
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43913

Project ID:
 Client ID: 197 MECHANIC ST

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	01/11/21 22:07	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	0.32	0.01	1	mg/L		4		01/11/21 12:02	*	SM4500Cl-G-00
pH	7.7	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

13:02
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43914

Project ID:
 Client ID: 249 POST RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	01/11/21 22:07	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	0.22	0.01	1	mg/L		4		01/11/21 13:02	*	SM4500Cl-G-00
pH	7.6	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

12:40
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43915

Project ID:
 Client ID: 20 AVONDALE RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	01/11/21 22:07	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	0.26	0.01	1	mg/L		4		01/11/21 12:40	*	SM4500Cl-G-00
pH	7.6	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

12:20
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43916

Project ID:
 Client ID: 110 OAK STREET

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	< 1	1	1	Color Units			15	01/11/21 22:07	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	0.57	0.01	1	mg/L		4		01/11/21 12:20	*	SM4500Cl-G-00
pH	7.6	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report
 January 13, 2021

FOR: Attn: Mr. Bill Beauregard
 Westerly Water Department
 68 White Rock Road
 Westerly, RI 02891

Sample Information

Matrix: DRINKING WATER
 Location Code: WESTERLY
 Rush Request: Standard
 P.O.#: 20190404-00

Custody Information

Collected by: PHOENIX
 Received by: B
 Analyzed by: see "By" below

Date

01/11/21
 01/11/21

Time

13:21
 15:36

Laboratory Data

SDG ID: GCH43911
 Phoenix ID: CH43917

Project ID:
 Client ID: 114 ASHAWAY RD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Escherichia Coli	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Total Coliforms	Absent	0	1	/100 mls		0		01/11/21 17:30	LJ/LJ	SM9223B-04
Color, Apparent	5.00	1	1	Color Units			15	01/11/21 22:07	AP/MW	SM2120B-11
Odor at Room Temperature	< 1	1	1	T.O.N.			3	01/11/21 22:08	AP/MW	SM2150B-97
Turbidity	< 0.20	0.20	1	NTU			5	01/11/21 22:15	AP	SM2130B-11
Chlorine Residual	0.33	0.01	1	mg/L		4		01/11/21 13:21	*	SM4500Cl-G-00
pH	7.7	1.00	1	pH Units			6.5-8.5	01/11/21	*	FIELD

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
-----------	--------	------------	-----	-------	----	-----	------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (MCL): 40 CFR Part 141. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): 40 CFR Part 141.80.


Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The chlorine result is provided by the client on the chain of custody.

The pH result is provided by the client on the chain of custody.

Bacteria Analysis Comment: This sample was treated for chlorine at time of sample collection with sodium thiosulfate.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.



Phyllis Shiller, Laboratory Director

January 13, 2021

Reviewed and Released by: Helen Geoghegan, Project Manager



Environmental Laboratories, Inc.
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
 Tel. (860) 645-1102 Fax (860) 645-0823

QA/QC Report

January 13, 2021

QA/QC Data

SDG I.D.: GCH43911

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
QA/QC Batch 559371 (NTU), QC Sample No: CH43676 (CH43911, CH43912, CH43913, CH43914, CH43915, CH43916, CH43917)													
Turbidity	BRL	0.20	0.33	0.32	NC	96.5						85 - 115	20

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference

Phyllis Shiller, Laboratory Director
 January 13, 2021

Wednesday, January 13, 2021

Criteria: RI: DW

State: RI

Sample Criteria Exceedances Report

GCH43911 - WESTERLY

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

January 13, 2021

SDG I.D.: GCH43911

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

CHAIN OF CUSTODY RECORD

587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040
 Email: service@phoenixlabs.com Fax (860) 645-0823

Client Services (860) 645-8726



Data Delivery (check one):
 Fax # _____
 Email: _____
 Format: Excel Pdf Gis Key

Project P.O.: _____
 Report to: Bill Beauregard Phone #: 401-348-2561
 Invoice to: Accounts Payable Fax #: _____

Customer: Westerly Water Department
 Address: 68 White Rock Road
 Westerly, RI 02891

Client Sample - Information - Identification

Sampler's Signature: Ed Walsh Date: 1/11/12

Matrix Code:
 DW=drinking water S=soil/solid O=other
 GW=groundwater SL=sludge A=air

Phoenix Sample #	Customer Sample Identification	Sample Matrix	Date Sampled	Time Sampled
43911	398 Liberty St	DW	1/11	11:30
43912	87 West Broad St	DW	1/11	11:49
43913	197 Mechanic St	DW	1/11	12:02
	416 Bradford Rd	DW		
	487 Westerly Bradford Rd	DW		
43914	249 Post Rd	DW	1/11	13:02
43915	20 Avondale Rd	DW	1/11	12:40
43916	110 Oak Street	DW	1/11	12:20
43917	114 Ashaway Rd.	DW	1/11	13:21
	8 Parkview	DW		
	68 White Rock Rd	DW		

Analysis Request	Total Coliform	PH	Total Chlorine	Soil VOA [Methanol] [S. Bisulfate] [H2O]	GL Soil container () oz	GL Amber 4 oz [As is] [X] HCl	PL H2SO4 [] 250ml [] 500ml [] 1000ml	PL H2SO4 [] 250ml [] 500ml	Bacteria Bottle
	X	8.0	1.19						
	X	7.7	.92						
	X	7.7	.32						
	X								
	X								
	X	7.6	.22						
	X	7.6	.26						
	X	7.6	.57						
	X	7.7	.33						
	X								
	X								
	X								

Relinquished by: Ed Walsh Accepted by: [Signature]
 Date: 1/11/12 Time: 1531p

Turnaround:
 1 Day*
 2 Days*
 3 Days*
 Standard
 Other
 * Surcharge Applies

Requirements for CT:
 Res. Criteria
 GW Protection
 GA Mobility
 GB Mobility
 SW Protection
 Res. Vol.
 Ind. Vol.

Requirements for MA:
 GW-1
 GW-2
 GW-3
 S-1
 S-2
 S-3
 MCP Certification
 Other

Comments, Special Requirements or Regulations: